

HOLLYM PARISH COUNCIL MINUTES TO MONTHLY MEETING HELD ON THE 16 JULY 2015 IN THE VILLAGE HALL

Present Cllr Dearing (Chair)
Cllr Boasman (Vice Chair)
Cllr Lindgren
Cllr Laycock
Cllr Ward
Cllr Burrell
Cllr Ives
Cllr Arthur Hodgson (ERYC Ward Councillor)
Cllr Lyn Healing (ERYC Ward Councillor)
Clerk Sue Barrick
Daniella Munton (YWA)
Fiona Sugden (YWA)
Lucy Ward (YWA)
Paul (YWA Contract Partners)

4 member of the public

1. DECLARATION OF PECUNIARY AND NON-PECUNIARY INTERESTS

Cllrs Burrell & Boasman declared pecuniary interests in item 4 on the agenda.

2. APOLOGIES

None.

3. MINUTES TO THE PREVIOUS MEETING

The minutes were approved and signed as a record.

4. YORKSHIRE WATER PROPOSALS

Fiona Sugden stated that the current water waste treatment works on the cliff top was estimated to be lost with 5 years with the outfall pipe being lost within 2 years. It is not cost effective to defend this site and it is not Government policy to defend coastlines as no funding was available. The asset life of a replacement works would need to be 100 years and 1.5 kilometres inland. It would also need to be 400 metres from any residential properties, not near any archaeological sites, be situated on suitable ground conditions and not on a flood plain. The site chosen from these surveys was at the end of North Carr Dales Road (locally known as Long Lane) and a new temporary road (which could become permanent) was to be constructed off the A1033 close to Pearcey Lane (subject to planning approval) Fiona stated that planning regulations are more stringent since the Hedon Road site as regards smell and traffic and that they were using different technology also. Hollym's sewerage systems would remain unchanged but there could be a possible financial benefit in the proposals for Hollym as regards supporting community projects ie Village Hall. Fiona stated that she could not guarantee that there would be no smell.

Cllr Burrell asked if there was a similar treatment plant that could be visited by villagers and Fiona stated that she could look into finding a similar plant and arrange a site visit. Fiona also mentioned that the proposed new works would be designed to manage the population up until 2030 and may take in the works of the Patrington plant too. After a question from a member of the public regarding connection of old plant to new plant Fiona stated that the existing pipe from cliff top would come under the main Hollym Road in Hollym and join in under the new proposed road to the new site. Construction traffic would also go down the new road. Cllr Hodgson asked for sight of the plans and planning application number and Fiona stated that she would supply this information. The new site is to be 225 metres x 125 metres which includes landscaping and bund which could be up to 3 metres high to protect site from and future flooding along with the assistance of pumps in case of need with minimal noise at exceptionally high water tides/tables. The tanks will be round open tanks with rotating arms spraying water to the top of the contents. A member of the public asked if the existing small works would be incorporated and Fiona stated possibly but would be looked at in the future. A

